



2021 IRC Question Of The Week

Each refrigeration system using Group A2L refrigerant shall have which of the following text legibly and permanently indicated on a markable label provided by the equipment manufacturer?

- A) Contact information of the responsible company that installed the refrigeration system.
- B) The system refrigerant charge.
- C) The refrigerant number.
- D) None Of The Above

This label requirement is not a code provision in the 2021 IRC but has been added to the 2024 code edition.

M1411.5 Signs and identification.

Each refrigeration system using Group A2L refrigerant shall have the following information legibly and permanently indicated on a markable label provided by the equipment manufacturer.

1. Contact information of the responsible company that installed the refrigeration system.
2. The system refrigerant charge and the refrigerant number.

