



2021 IFGC Question Of The Week

The termination of required concealed condensate piping serving a fuel-burning appliance shall be marked to indicate whether the piping is connected to the _____.

- A) primary drain only
- B) secondary drain only
- C) primary drain or to the secondary drain
- D) Marking not required by the IFGC.



307.2 Fuel-burning appliances.

Liquid combustion byproducts of condensing appliances shall be collected and discharged to an approved plumbing fixture or disposal area in accordance with the manufacturer's instructions. Condensate piping shall be of approved corrosion-resistant material and shall be not smaller than the drain connection on the appliance. Such piping shall maintain a minimum slope in the direction of discharge of not less than 1/8 unit vertical in 12 units horizontal (1 percent slope). The termination of concealed condensate piping shall be marked to indicate whether the piping is connected to the primary drain or to the secondary drain.



NOTICE

**HVAC
CONDENSATE
SECONDARY DRAIN**

NOTICE

**HVAC
CONDENSATE
PRIMARY DRAIN**